

## DECLARACIÓN DE PRESTACIONES

Según el Reglamento de productos de la construcción n.º305/2011 del Parlamento Europeo

**N. 47622897**

**1. Código de identificación único del tipo de producto:**

Cerradura salida de emergencia / Cerradura antipánico Series “Fast Push”.

**2. Tipo, lote o número de serie o cualquier otro elemento que permita la identificación como se establece en el artículo 11, apartado 4:**

**Series** “FAST PUSH” 1.59001.10.0.xx.xx.xx, 1.59011.10.0.xx.xx.xx,  
1.59016.10.0.xx.xx  
**Bars** mod. 1.07007.13/60.0.xx, 1.07007.14/61.0.xx, 1.07007.15/62.0.xx  
**Locking points** 1.07063.51.0.xx.xx.xx, 1.07063.61.0.xx.xx.xx,  
1.07063.66.1/2.xx.xx.xx, 1.07063.71.0.xx.xx, 1.07063.26.1/2.xx.xx.xx,  
1.07063.53.0.xx.xx.xx,  
**Strikes and plates** 1.07083.xx.0.xx, 1.07072.xx.0.xx, 1.07090.01.0.xx,  
1.07090.10.0.xx, 1.07091.xx.0.xx  
**Handles** 1.07078.2x.0.xx, 1.07077.4x.0.xx, 1.07074.80.0.xx, 1.07078.3x.0.xx,  
1.07078.6x.0.xx,  
**Rods** 1.07064.80.0.xx.xx

**3. Uso o usos previstos del producto de construcción, con arreglo a la especificación técnica armonizada aplicable, tal como lo establece el fabricante:**

Puertas en vías de evacuación

**4. Nombre o marca registrados de contacto del fabricante según lo dispuesto en el artículo 11, apartado 5:**

CISA S.p.A – Via Oberdan 42, 42018 Faenza (RA) Italy

**5. En su caso, nombre y dirección de contacto del representante autorizado cuyo mandato abarca las tareas especificadas en el artículo 12, apartado 2:**

N/A

Pag. 1/4

**6. Sistema o sistemas de evaluación y verificación de la constancia de las prestaciones del producto de construcción tal como figura en el anexo V:**

Sistema 1

**7. En caso de declaración de prestaciones relativa a un producto de construcción cubierto por una norma armonizada:**

Norma armonizada: EN1125:2008

Organismo notificado: ICIM S.p.A. – Piazza Don Mapelli 75 – 20099 Sesto San Giovanni (MI) Italy, N. 0425

ha realizado la evaluación y verificación de la constancia de rendimiento conforme al:  
Sistema 1

y expedido el certificado de conformidad: 0425-CPR-002288

**8. En caso de declaración de prestaciones relativa a un producto de construcción para el que se ha emitido una evaluación técnica europea:**

NA

**9. Rendimiento declarado:**

| Essential Characteristic                                      | Performance                   | Harmonised technical specification |
|---------------------------------------------------------------|-------------------------------|------------------------------------|
| <b>Ability to release (for locked doors on escape routes)</b> |                               |                                    |
| Release function                                              | $\leq 1$ s                    | EN1125:2008 par. 4.1.2             |
| Panic exit device mounting                                    | Pass                          | EN1125:2008 par. 4.1.3             |
| Exposed edges and corners                                     | $\geq 0,5$ mm                 | EN1125:2008 par. 4.1.5             |
| Double doorset                                                | Pass                          | EN1125:2008 par. 4.1.7             |
| Bar installation                                              | $Z \leq 150$ mm               | EN1125:2008 par. 4.1.9             |
| Bar length                                                    | $\geq 60$ % of the door width | EN1125:2008 par. 4.1.10            |
| Bar projection                                                | $W = 94$ mm                   | EN1125:2008 par. 4.1.11            |
| Bar end                                                       | Pass                          | EN1125:2008 par. 4.1.12            |

Pag. 2/4

|                                                                                                                   |                                      |                                                      |
|-------------------------------------------------------------------------------------------------------------------|--------------------------------------|------------------------------------------------------|
| Operating bar face                                                                                                | V = 30 mm                            | EN1125:2008 par. 4.1.13                              |
| Test rod                                                                                                          | Pass                                 | EN1125:2008 par. 4.1.14                              |
| Door face gap                                                                                                     | R= />25 mm                           | EN1125:2008 par. 4.1.15                              |
| Accessible gap                                                                                                    | Pass                                 | EN1125:2008 par. 4.1.16                              |
| Door free movement                                                                                                | Pass                                 | EN1125:2008 par. 4.1.17                              |
| Top vertical bolt                                                                                                 | Pass                                 | EN1125:2008 par. 4.1.18                              |
| Keepers                                                                                                           | Pass                                 | EN1125:2008 par. 4.1.20                              |
| Keepers dimensions                                                                                                | H <= 15 mm M <=45° P<= 3 mm          | EN1125:2008 par. 4.1.21                              |
| Door mass and dimensions                                                                                          | Grade 7                              | EN1125:2008 par.4.1.23 6.3.2 6.3.4 6.3.5 6.3.6 6.3.8 |
| Outside access device                                                                                             | Pass                                 | EN1125:2008 par. 4.1.24 6.3.2                        |
| Release forces                                                                                                    | <= 80 N e/and <= 220N under pressure | EN1125:2008 par.4.2.2 6.3.2                          |
| Security requirement                                                                                              | Grade 2                              | EN1125:2008 par. 6.3.7                               |
| <b>Durability of ability to release(for locked doors on escape routes)</b>                                        |                                      |                                                      |
| Corrosion resistance                                                                                              | Grade 4; 240h salt spray fog         | EN1125:2008 par. 6.2.3                               |
| Temperature range                                                                                                 | ( -10°C / +60° C)<br>50 % in excess  | EN1125:2008 par. 6.2.2                               |
| Covers for vertical rods                                                                                          | 500 N                                | EN1125:2008 par. 4.1.19 6.3.6                        |
| Lubrication                                                                                                       | 20 000 cycles                        | EN1125:2008 par. 4.1.22 6.3.4                        |
| Re-engagement force                                                                                               | <= 50 N                              | EN1125:2008 par. 4.2.3 6.3.3                         |
| Durability                                                                                                        | Grade 7; 200000cycles                | EN1125:2008 par.4.2.4 6.3.4                          |
| Abuse resistance – Horizontal bar                                                                                 | 1000 N                               | EN1125:2008 par. 4.2.5 6.3.5                         |
| Abuse resistance – Vertical rod                                                                                   | 500 N                                | EN1125:2008 par. 6.3.6 or 4.1.19 4.2.6               |
| <b>Self closing ability C against aging and degradation (for fire/smoke doors on escape routes)</b>               |                                      |                                                      |
| Re-engagement force                                                                                               | Threshold (<= 50 N)                  | EN1125:2008 par. 6.3.3                               |
| <b>Durability of Self closing ability C against aging and degradation (for fire/smoke doors on escape routes)</b> |                                      |                                                      |
| Durability                                                                                                        | Grade 7, 200000cycles                | EN1125:2008 par. 6.3.4                               |
| Re-engagement force                                                                                               | Threshold (<= 50 N)                  | EN1125:2008 par. 6.3.3                               |
| <b>Dangerous substances</b>                                                                                       |                                      |                                                      |
| Control of dangerous substances                                                                                   | Pass                                 | EN1125:2008 par. 4.1.25                              |



CISA S.p.A. a socio unico (single shareholder plc)  
Via G. Oberdan 42 48018 Faenza (RA) Italy  
Ph +39 0546 677111 Fax +39 0546 677150  
P.O. Box 72 cisa.com allegion.com  
Cap. Soc. Euro 11.471.968,56 i.v. R.E.A. RA 166664  
Reg. Imprese e Cod. Fisc. 08396850151  
Part. IVA 03664620378

Soggetta a direzione e coordinamento da parte di:  
(subject to the coordinating authority of)  
Allegion plc

**10. Las prestaciones del producto identificado en los puntos 1 y 2 son conformes con las prestaciones declaradas en el punto 9.**

La presente declaración de prestaciones se emite bajo la sola responsabilidad del fabricante identificado en el punto 9.

Firmado por y en nombre del fabricante por

Faenza (RA) 01/08/2022  
(lugar y fecha de emisión)

CISA - Legal Representative

(firma)